

CERTIFICATE OF ANALYSIS 146638

Client:

Cash Sale
PO Box 425
Maylands
WA 6931

Attention: W B Day

Sample log in details:

Your Reference:	<u>William B Day</u>
No. of samples:	1 x material
Date samples received:	19/02/14
Date completed instructions received:	19/02/14
Location:	

Analysis Details:

Please refer to the following pages for results, methodology summary and quality control data.
Samples were analysed as received from the client. Results relate specifically to the samples as received.

Please refer to the last page of this report for any comments relating to the results.

Report Details:

Date results requested by:	21/02/14
Date of Preliminary Report:	Not Issued
Issue Date:	21/02/14

NATA accreditation number 2901. This document shall not be reproduced except in full.
Accredited for compliance with ISO/IEC 17025.

Tests not covered by NATA are denoted with *.

Results Approved By:



Lalanee Rupasinghe
Approved Signatory

Asbestos ID - materials			
Our Reference:	UNITS	PQL	146638-1
Your Reference	--	--	Construction Rubble
Type of sample	--	--	Material
Date analysed	-		20/02/14
Sample Dimension	mm		60x50x4
Sample Description	-		Fibre Cement Material
Asbestos ID in materials	-		Chrysotile asbestos detected

Method ID	Methodology Summary
ASB-001	Asbestos ID - Qualitative identification of asbestos in bulk samples using Polarised Light Microscopy and Dispersion Staining Techniques, including Synthetic Mineral Fibres (SMF) and Organic Fibres, as per Australian Standard AS4964-2004.

Report Comments:

INS: Insufficient sample for this test; NT: Not tested; PQL: Practical Quantitation Limit; <: Less than; >: Greater than
RPD: Relative Percent Difference; NA: Test not required; LCS: Laboratory Control Sample;
NS: Not specified;
DOL: Sample rejected due to particulate overload

Asbestos was analysed by Approved Identifier:	Lalanee Rupasinghe
Airborne Fibres were analysed by Approved Counter:	Not applicable for this job
Airborne Fibres sampled by:	Not applicable for this job